

DATE: October 4, 2019

DEPARTMENT OF GENERAL SERVICES
BUREAU OF PRE-CONSTRUCTION
1800 HERR STREETS
HARRISBURG, PENNSYLVANIA

ADDENDUM NO. 1

on

PROJECT NO. DGS A-0199-0087 PHASE 001

PROJECT TITLE - Meadow Grounds Lake Dam - Rehabilitation Dam

PROFESSIONAL:

D'Appolonia Engineering Division of Ground Technology, Inc.
701 Rodi Road, Floor 2
Pittsburgh, PA, 15235

If you submitted a bid through e-Builder prior to this Addendum being issued, your bid has been discarded and you must re-submit your bid(s) through e-Builder prior to the bid opening date and time. Please see Section 4.C. of the Instruction to Bidder

GENERAL CHANGES – ALL CONTRACTS

Item 1 - GENERAL CLARIFICATION: Specification Section 03 30 00, Cast-in-Place Concrete: A specification for the required amount of drying shrinkage is not available at this time. The dosage for the Shrinkage Reducing Admixture (SRA) will be finalized as part of the submittal and approval process for ready mix concrete. For bidding purposes, it is anticipated that the dosage rate of SRA will be within the manufactures recommended range (ex. 0.5 to 1.5 gal/CY for MasterLife SRA035).

Item 2 - GENERAL CLARIFICATION: Drawing C-16, Dam Rehabilitation Sequence Stage 3, Item 1: The longitudinal (direction of water flow) contraction/expansion joints extend vertically down the cutoff wall from the upstream most slab and are the only joints permitted in the cutoff wall. Transverse (horizontal) joints between the spillway slab and cutoff wall or otherwise are not permitted. Contraction joints shall be per detail S-6/1 and expansion joints shall be per detail S-6/4.

SPECIFICATION CHANGES – ALL CONTRACTS

Item 1 - Section 03 30 00, Cast-in-Place Concrete: ADD new paragraph 2.2.A.4.b to read as follows: "b. Shrinkage Reducing Admixtures (SRA) shall be used, as required to reduce concrete shrinkage. Shrinkage Reducing Admixture MasterLife SRA035, Euclid Eucon SRA-XT, or equal as approved by the Professional are acceptable."