

DATE: October 17, 2019

DEPARTMENT OF GENERAL SERVICES  
BUREAU OF PRE-CONSTRUCTION  
1800 HERR STREETS  
HARRISBURG, PENNSYLVANIA

**ADDENDUM NO. 2**

on

**PROJECT NO. DGS C-0251-0094 PHASE 001**

**PROJECT TITLE - District 6-0 Montgomery County Office - New Generator**

**PROFESSIONAL:**

PennDOT-FMD

1002 Hamilton Street

Allentown, PA, 18101

**If you submitted a bid through e-Builder prior to this Addendum being issued, your bid has been discarded and you must re-submit your bid(s) through e-Builder prior to the bid opening date and time. Please see Section 4.C. of the Instruction to Bidder**

**GENERAL CHANGES – ALL CONTRACTS**

Item 1 - DBC is responsible for identifying, obtaining, and paying for all applicable permits.

Item 2 - If the DBC is a certified SB or SDB, the proposer should answer the applicable question under Proposer (Prime Contractor) Information, completing the appropriate status designation as a DGS-Self-Certified Small/Diverse Business. The Percentage Commitment Information and Listing are for listing the subcontracting commitments. If further clarification is needed, use the contact information in Appendix E of the RFP.

Item 3 - The existing construction drawings show that the 3000 amp busway is fed by eight (8) parallel sets of 4#500kCMIL & 1#1/0GND in 4”CND which are run in an underground duct bank with two (2) 4” CND as “spare”. On the bridging documents, the existing busway is to be fed by 1000 amp breaker and feeder. This reduced ampacity was calculated using historic electrical load data.

Item 4 - PennDOT District 6-0 has an existing maintenance contract with CM3 Building Solutions for the building automation system. This is presented for informational purposes only. The DBC is responsible for all Controls/BAS vendor work as described in specification section 230993.11.

**SPECIFICATION CHANGES – ALL CONTRACTS**

N/A

**DRAWING CHANGES – ALL CONTRACTS**

N/A