

DATE: January 26, 2023

DEPARTMENT OF GENERAL SERVICES
BUREAU OF CAPITAL PROJECT DESIGN MANAGEMENT
1800 HERR STREETS
HARRISBURG, PENNSYLVANIA

ADDENDUM NO. 17

on

PROJECT NO. DGS C-0210-0004 PHASE 001

PROJECT TITLE - PA State Police Greensburg - DNA Laboratory Facility New Building

PROFESSIONAL:

DRS Architects, Inc.

One gateway Center

Pittsburgh, PA, 15222

If you submitted a bid prior to this Addendum being issued, your bid has been discarded and you must re-submit your bid(s) prior to the bid opening date and time.

GENERAL CHANGES – ALL CONTRACTS

Item 1 - The cut off for questions submitted in e-Builder was CoB 11/11/22, and no further questions will be answered following this addendum.

Item 2 - Refer to the Addendum 17 document attached to this addendum.

SPECIFICATION CHANGES – ALL CONTRACTS

Item 1 - N/A

DRAWING CHANGES – ALL CONTRACTS

Item 1 - N/A

January 25, 2023

DGS 0210-0004
PA State Police Greensburg
New DNA Laboratory Facility

ADDENDUM 17

Item	Description
Item 1	<p>The deadline for submitting bidding questions was Nov 11th, as stated in Addendum 10. Since that time a few additional questions were submitted, and they are answered below. Questions received after this addendum will not be answered.</p> <p>Questions and responses:</p> <p>1) <i>Jeffrey Mascaro, Mascaro Construction Company, L. P., 01.23.2023 12: 51 PM Eastern Time: Are there any changes to the scope of work or the PLA requirements, due to the resolution of the protest?</i></p> <p>Response: There are no changes to the scope of work or the P.L.A.</p> <p>2) <i>Fred Meucci, Hranec Sheet Metal, Inc., 01.23.2023 10: 43 AM Eastern Time: Do the signed bid docs need to reflect the new Feb.14 ,2023 date on them, or can we use our signed bid documents from Nov. 2022?</i></p> <p>Response: The date on the signed documents should be updated.</p> <p>3) <i>Ron Smith, DiMarco Construction Co. Inc., 01.24.2023 03:36 PM Eastern Time: Which Prime Contractor is responsible for the site storm system, site water, site sanitary, and site gas utilities?</i></p> <p>Response: The .1 (General) Contractor is responsible for all site sewer, water, and gas work up to 5'-0" from building/service yard wall. The point of utility connections are noted and identified on the drawings and typically noted as 5'-0" of the building exterior wall. Refer to Plumbing Drawings.</p> <p>4) <i>Lori Ruzzi, Bob Biter Electrical Enter, Inc., 01.16.2023 12:21 PM Eastern Time: Addendum 11 page 2 references attached drawings page 11 & 12 reference revised sheet E605. But no drawings were attached?</i></p> <p>Response: Our records indicate that the drawings were attached to the addendum.</p>

Thank you,



Jon Funari
DRS Architects